

WELL CONSTRUCTION AND TEST REPORT STATE OF COLORADO, OFFICE OF THE STATE ENGINEER 1313 Sherman St., Rm 818, Denver, CO 80203

For Office Use only

1. WELL PERMIT NUMBER 177031-A

2. OWNER NAME(S) F. Scott Hendricks Mailing Address P.O. Box 882915 City, St. Zip Steamboat Springs, Colo 80488 Phone (970) 846-0710

3. WELL LOCATION AS DRILLED: NE 1/4 NE 1/4, Sec. 15 Twp. 7 N, Range 85 W DISTANCES FROM SEC. LINES: 750 ft. from NORTH Sec. line. and 400 ft. from EAST Sec. line. OR SUBDIVISION: ELK RIVER MTN RANCH LOT 17 BLOCK FILING(UNIT) STREET ADDRESS AT WELL LOCATION:

4. GROUND SURFACE ELEVATION ft. DRILLING METHOD AIR PERCUSSION DATE COMPLETED October 7, 2003. TOTAL DEPTH 220 ft. DEPTH COMPLETED 220 ft.

5. GEOLOGIC LOG: Table with columns for Depth and Description of Material. Entries include 0-1 topsoil, 1-160 Sandstone + claystone, 160-215 Sandstone w/ some claystone + siltstone, 215-220 Fractured sandstone.

6. HOLE DIAM. (in.) From (ft) To (ft) Table with entries: 9, 6 1/2, 0, 41, 220

7. PLAIN CASING Table with columns for OD (in), Kind, Wall Size, From(ft), To(ft). Entries include 7 steel, 5 PVC, 5 PVC.

8. FILTER PACK: NA Material Size Interval

9. PACKER PLACEMENT: Type Depth

10. GROUTING RECORD: Material Amount Density Interval Placement. Entries include portland cement, 5 sacks, 10-40, vibration.

11. DISINFECTION: Type HTH Amt. Used 2 oz

12. WELL TEST DATA: TESTING METHOD AIR Static Level 180 ft. Date/Time measured 10-7-03, Production Rate 8 gpm. Pumping level 210 ft. Date/Time measured 10-7-03, Test length (hrs.) 1

13. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge. CONTRACTOR ARROW DRILLING CO Phone (303) 421 8766 Lic. No. 1215. Mailing Address 2127 Elderberry Rd Golden, Colo 80401

Name/Title (Please type or print) Peter R Berglund / Dr. Signature Date 10/27/03

FORM NO.
GWS-32
11/90

PUMP INSTALLATION AND TEST REPORT

STATE OF COLORADO, OFFICE OF THE STATE ENGINEER

For Office Use only

1. WELL PERMIT NUMBER 177031 A

2. OWNER NAME(S) E SCOTT HENDRICKS
Mailing Address Box 88 2915
City, St. Zip SBS CO 80488
Phone (970) 0710

3. WELL LOCATION AS DRILLED: NE 1/4 NE 1/4, Sec. 15 Twp. 7 N, Range 85 W
DISTANCES FROM SEC. LINES:
750 ft. from N Sec. line. and 400 ft. from E Sec. line.
(north or south) (east or west)
SUBDIVISION: ELK RIVER MTR RANCH LOT 17 BLOCK _____ FILING(UNIT) _____
STREET ADDRESS AT WELL LOCATION: _____

4. PUMP DATA: Type Sub Installation Completed 11/01/03
Pump Manufacturer GOULD Pump Model No. 106507412
Design GPM 10 at RPM 345, HP 3/4, Volts 230, Full Load Amps 8
Pump Intake Depth 200 Feet, Drop/Column Pipe Size 1 Inches, Kind PVC
ADDITIONAL INFORMATION FOR PUMPS GREATER THAN 50 GPM:
TURBINE DRIVER TYPE: Electric Engine Other _____
Design Head _____ feet, Number of Stages _____, Shaft size _____ inches.

5. OTHER EQUIPMENT:
Airline Installed Yes No, Orifice Depth ft. _____ Monitor Tube Installed Yes No, Depth ft. _____
Flow Meter Mfg. _____ Meter Serial No. _____
Meter Readout Gallons, Thousand Gallons, Acre feet, Beginning Reading _____

6. TEST DATA: Check box if Test data is submitted on Supplemental Form.
Date 10/14/03 10/14/03 10/14/03
Total Well Depth 220' Time 1640 1700 1730
Static Level 161' Rate (GPM) 10 10 10
Date Measured 10/14/03 Pumping Lvl. 161 162 162

7. DISINFECTION: Type HTH Amt. Used 402

8. Water Quality analysis available. Yes No

9. Remarks _____

10. I have read the statements made herein and know the contents thereof, and that they are true to my knowledge.
[Pursuant to Section 24-4-104 (13)(a) C.R.S., the making of false statements herein constitutes perjury in the second degree and is punishable as a class 1 misdemeanor.]

CONTRACTOR B & J PUMP and WELL SERVICE
1280 - 13TH STREET UNIT F Phone (970) 879-6132 Lic. No. 1107
P.O. BOX 772740
Mailing Address STEAMBOATS SPRINGS, CO 80477

Name/Title (Please type or print) ROBERT T. BROWN / Pres Signature Robert T. Brown Date 12/22/03
LIC #1107